

Reaction to fire



The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2021AN0211



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

N° 21AN0211

The sample reference:

“SOIE CHANGEANTE”

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“B-s2,d0”

Alcoy, February 10th 2021.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.